

- FOUNDATION NOTES:

- CONCRETE NOTES:

- | ELEMENT     | CONCRETE STRENGTH<br>AT 28 DAYS (MPa) | COVER<br>(mm) |
|-------------|---------------------------------------|---------------|
| FOUNDATION  | 25                                    | 50            |
| BEAM        | 25                                    | 30            |
| SLAB        | 25                                    | 30            |
| SURFACE-BED | 25                                    | 25            |

- JOINT SEALANT NOTES:

- MASONRY NOTES

- THE MINIMUM CRUSHING STRENGTH OF ALL LOAD BEARING BRICKS SHALL BE 14 MPa
- MORTAR SHALL BE CLASS (ii)
- BRICKWORK SHALL BE BUILT ACCORDING TO SABS 0164

No	DATE	DESCRIPTION	INTL	APPR
REVISIONS				

DRAWN BY: W.N	DESIGNED BY: W.N
---------------	------------------



Gaborone City Council

GABORONE DISABLED PERSONS SOCIETY  
DEPARTMENT OF LOCAL GOVERNMENT  
AND DEVELOPMENT  
Private bag 0089,Gaborone

APPLICATION FOR PLANNING AND  
BUILDING PERMISSION FOR A CIVIC  
COMMUNITY (REHABILITATION CENTER)  
ON PLOT 37233,BLOCK 8,GABORONE

### RING BEAM REINFORCEMENT LAYOUT

