

- FOUNDATION NOTES:

- CONCRETE NOTES:

- | ELEMENT | CONCRETE STRENGTH
AT 28 DAYS (MPa) | COVER
(mm) |
|-------------|---------------------------------------|---------------|
| FOUNDATION | 25 | 50 |
| BEAM | 25 | 30 |
| SLAB | 25 | 30 |
| SURFACE-BED | 25 | 25 |

- JOINT SEALANT NOTES:

- MASONRY NOTES

- THE APPLICABLE STANDARD SPECIFICATION IS
SABS 227 : BURNT CLAY BRICKS.
SABS 1215 : CEMENT BRICKS.
- THE MINIMUM CRUSHING STRENGTH OF ALL
LOAD BEARING BRICKS SHALL BE 14 MPa
- MORTAR SHALL BE CLASS (ii)
- BRICKWORK SHALL BE BUILT ACCORDING TO SABS 0164

No	DATE	DESCRIPTION	INTL	APPR
REVISIONS				

DRAWN BY: W.N

DATED: 15/06/2022

APPROVED BY: B.B.K



PROJECT

TITLE

DRAWING No. GCC/AB/SE/108 Rev 0.