

- FOUNDATION NOTES:

- CONCRETE NOTES:

- | ELEMENT | CONCRETE STRENGTH
AT 28 DAYS (MPa) | COVER
(mm) |
|-------------|---------------------------------------|---------------|
| FOUNDATION | 25 | 50 |
| BEAM | 25 | 30 |
| SLAB | 25 | 30 |
| SURFACE-BED | 25 | 25 |


- JOINT SEALANT NOTES:

- MASONRY NOTES

- THE MINIMUM CRUSHING STRENGTH OF ALL LOAD BEARING BRICKS SHALL BE 14 MPa
- MORTAR SHALL BE CLASS (ii)
- BRICKWORK SHALL BE BUILT ACCORDING TO SABS 0164

No	DATE	DESCRIPTION	INTL	APPR
REVISIONS				

DRAWN BY: W.N. CHECKED BY: B.B.K



Gaborone City Council

GABORONE DISABLED PERSONS SOCIETY
DEPARTMENT OF LOCAL GOVERNMENT
AND DEVELOPMENT
Private bag 0089,Gaborone

APPLICATION FOR PLANNING AND
BUILDING PERMISSION FOR A CIVIC
COMMUNITY (REHABILITATION CENTER)
ON PLOT 37233,BLOCK 8,GABORONE

RING BEAM LAYOUT